LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 06/10/2025 Expiration Date: 06/09/2026 Permit# 25-2898

Property Owner: Sabrina Robinson

Mailing Address: 3420 S Whipple Rd, Spokane, WA 99206

Installer: Terry Oedewaldt License #: 2

Approved Work: (Check One) ☒ New Installation ☒ Existing System

If existing: ☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Replace existing 3-bedroom system with new 4-bedroom system

Legal: Crystal Lake Shore Lots, Lot 33, S30 T27N R27W, Plat 499

Property Address: 232 E. Crystal Lake Rd., Libby MT 59923 Assessment Code: 2898

DEQ E.Q.# NA Date: NA

Approved Design Criteria: Install 1500 gallon septic tank with effluent filter, 500 gallon pump tank, and pressure-dosed drainfield with chambers. 25% reduction given for chambers.

# of Bedrooms: 4 Septic Tank Size: 1500/500 Trench Width: 36"

# of Laterals: 3 Lateral Length: 50' each Trench Depth: 24"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kathi Hooper, RS*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to pressure distribution field test and backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system has been inspected and is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Dylan Blumler *Date:* 11/20/25

This permit is not finalized until the system is inspected and the closure statement is signed.

This permit is not a guarantee that the system will function properly for a prescribed period of time.

ROBINSON SEPTIC 11/20/25

LOCATIONS:	A	B
INLET	14'1	33'3
FILTER	23'	24'7
PUMP	25'4	27'6
1 CLOUT	86'2	44'6
2 CLOUT	86'10	46'6
3 CLOUT	87'7	49'2

