LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 09/10/2025 Expiration Date: 09/09/2026 Permit#25-53693

Property Owner: Andrew and MariRuth Smith

Mailing Address: [redacted]

Installer: Terry Oedewaldt License #: 2

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of new gravity system for 1 Bedroom Cabin.

Legal: S17, T29 N, R30 W, COS 5094, PARCEL A, ACRES 25

Property Address: 514 Zion Hill Rd., Libby, MT 59923 Assessment Code: 53693

DEQ COSA: E.Q.# Date:

Approved Design Criteria: Installation of new gravity system for 1 Bedroom Cabin with 3 Laterals @ 60' with reduction for chambers. Drainfield sized for 1 Bedroom Cabin and 2 Bedroom Cabin 375 GPD.

# of Bedrooms: 1 Septic Tank Size: 1000 Trench Width: 24"

# of Laterals: 3 Length of Laterals: 60' Trench Depth: 18"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, Circular DEQ-4, and COSA(If Applies). Reduction given for chambers. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Robin Blumberg, RS*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:


This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Robin Blumberg Date: 11/5/25

This permit is not finalized until the system is inspected and the closure statement is signed.

This permit is not a guarantee that the system will function properly for a prescribed period of time.

ANDREW & MARI RUTH SMITH SEPTIC 11/5/25



LOCATIONS:

	A	B
INLET	11'3	28'1
FILTER	14'11	34'
D-BOX	75'3	101'9

PARCEL MAP

