LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 07/23/2012 Expiration Date: 07/24/2013

Property Owner: Phil & Sharon Clouse c/o:

Address: [redacted]

Telephone: (Home) [redacted] (Work)

Installer: Linda Garrison License No. 114

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: Using gravelless chambers – sizing reduction allowed per "Drainfield Size" below.

Parcel Description:

Legal: T36 R31

Address or Location: Lot 18 in Block 2 of Yaak Meadows -- Tamarack Lane

Approved Design Criteria:

Bedrooms: 2 Septic Tank Size: 1000 gallons Drainfield Size: 112 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____


NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT


YAAK RIVER
100'
83'
100'
19
(1.05 AC)
18
(1.17 ac)
17
(1,12 ac)
356'
329'
595'
592'
DROPOFF TO
20'-32'
56.68'
DBOX
SEPTIC TANK
10'
REPLACEMENT
20-30'
HOUSE
100'
HILL
150'
HILL
135'
HILL
95.6'
TAMARACK LANE
FLAT BETWEEN DROPOFF & HILL
I WILL REMEASURE TO MAKE SURE OF THE 100'