LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 07/08/2011 Expiration Date:

Property Owner: George & Cathy Fraser c/o: Kootenai Sand & Gravel, Inc.

Address: [redacted]

Telephone: (Home) (Work) [redacted]

Installer: Kootenai Sand & Gravel License No. 109

XX New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Install five 90-foot trenches for 4-bedroom residence.

Parcel Description:

Legal: SW-1/4 S26 T36 R28 Lot 1 of Yarnell Subdivision

Address or Location: Annerly Ferry Road

Approved Design Criteria:

Bedrooms: 4 Septic Tank Size: 1500 gallons Drainfield Size: 450 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET II

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kenneth J. Lind R.S.

Closure Statement:

I, Donavan D. Truman, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Donavan D. Truman *Date:* 7/15/2011

Title: RS

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.


406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Lot 1 Yarnell Subdivision

George & Cathy Fraser



reserve field

Drain field

Well

1500 gallon tank

House & garage sites