LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 08/23/2012 Expiration Date: 08/24/2013

Property Owner: Jeffery Gimbel c/o:

Address: [redacted]

Telephone: (Home) (Work)

Installer: Murphy Wagar License No. 72

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: Level II system with shallow-capped, pressure-dosed drainfield per DEQ approval requirements (E.Q. #08-1226)

Parcel Description:

Legal: S13 T27 R28 Lot 10 in Parkside at Fisher River

Address or Location: 529 Rogers Mountain Loop

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000 gallons Drainfield Size: 168 Linear Feet

Orenco Advantex Level 2 Unit – Drainfield to consist of two 84-foot lines in 3-foot wide trenches

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL LEVEL II SYSTEM ACCORDING TO DEQ APPROVAL #08-1226, LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Provide as-built on completion

