PERMIT

Issue Date: 5-13-93 Permit No. _____

Property Owner: CALVIN McDOUGALL c/o: Kooconusa Plumbing

Address: Spearwood, B.C. Canada

Telephone: (Home) _____ (Work) _____

Installer: Kooconusa Plumbing License No. 08

_X_ New Installation ___ Existing System

___ Repair ___ Replacement ___ Extension ___ Other

Describe: _____

Parcel Description:

Legal: LOT 5, Block 2, Amended Plat of Glen Lake Park

Address or Location: _____

Approved Design Criteria:

Septic Tank Size: 1000 gallons Proposed Drainfield Size: 180 lineal feet

Special Instructions: Construct septic system as per lot layout & County Wastewater Regulation #3

Approved Site plan (Lot Layout) Attached

Issued By: John W Peterson, RS.

Closure Statement:

I, Michael Nelson, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* 29 June 93

Title: _____

N
Approx 180' to Glen Lake
Replacement Area
25'
Slope
10'
60'
Drain Field
10'
10'
10'
Distribution Box
Septic Tank
House
100'
Driveway
well
102.72'
Public Rd Easement
Property line