LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 06/28/2010 Expiration Date: 06/29/2011

Property Owner: Shelley Derryberry c/o:

Address: [redacted]

Telephone: [redacted] (Work) 253-4869

Installer: Owner License No.

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: Significant drop in elevation from tank to drainfield – installation of a surge box will be required ahead of distribution box placement.

Parcel Description:

Legal: NW-1/4 S30 T32 R28

Address or Location: Lot 27 of McAlmond Claims

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1500 gallons Drainfield Size: 300 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER


This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT

McALMOND CLAIM, LOT 27
(REMOVAL OF SANITARY RESTRICTIONS)
NW1/4, SEC. 30 T32N R28W
LINCOLN COUNTY, MONTANA

Department of Environmental Quality/ PCD
Local Reviewer — 1/29/2009 Date

Accepted under contract
DEQ Representative — 2-4-09 Date



RECEIVED
JAN 30 2009
MT DEQ PUBLIC WATER & SUBDIVISION BUREAU

PREPARED BY: JOHN W. PETERSON