

**LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT**

Issue Date: 03/22/2010

Expiration Date: 03/23/2011

Property Owner: Kevin Garcia

c/o: Ronald Garcia

Address: [REDACTED]

Telephone: [REDACTED]

Installer: Bill Merritt

License No. 76

☒ XX New Installation ☐ Existing System
☐ Repair ☐ Replacement ☐ Extension ☐ Other

Describe: Installing pressure-dosed system per DEQ Approval requirements. Two 62-foot pressure-dosed lines in 3-foot wide trenches for a 3-bedroom system.

Parcel Description:

Legal: S27 T32 R34 Lot12 in Block 7 of Kootenai Vista Annex

Address or Location: 35 Vacation Road

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000 gallons Drainfield Size: 375 Square Feet
Dosing Tank Size: 500 gallons

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL PRESSURE-DOSED SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Konda J. Lind, P.E.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.


Signed: *William J. Merritt* Date: *5-20-10*

Title: *Owner*

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER





ELY NO 052 114

LINCOLN COUNTY, MONTANA
 LOT LAYOUT
 KOOTENAI VISTA ANNEX BLOCK 7 LOT 12
 IN THE NE 1/4 OF SECTION 27
 TWP. 32 N., R. 34 W., P.M.M.
 FOR: KROUPA DATE: APRIL 2004



LEGEND

-  SOILS PROFILE
-  PERCOLATION SITE
-  EXISTING WELL SITE
-  STORM WATER POND 30'X 20'X 2'
-  SLOPE
-  GRADIENT DIRECTION
-  PROPOSED SEPTIC SITE
~~3-63'~~ TRENCHES 2-63' in
 10' APART 3' wide pressure
 7' closed trenches
-  REPLACEMENT SITE
 3-85' TRENCHES
 10' APART
-  NATURAL SWALE 1.5'X 80'X .5'
-  100' MIXING ZONE



NO SEPTICS
 WITHIN 100' OF
 PROPERTY BOUNDARIES

APPROVED
 Montana Department of
 Environmental Quality
 Permitting and Compliance Division

Reviewer

Date

RECEIVED

OCT 04 2004

Department of
 Environmental Quality
 Kalispell Regional Office

SCALE
 1 INCH = 100 FT.

DAVIS SURVEYING INC.
 (406)295-5441

DATE: MARCH 2004

DRAWN BY: MDM FILE: T32R3427