LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 06/22/2010 Expiration Date: 06/23/2011

Property Owner: Richard R. & Keri K. Geldrich c/o:

Address: 161 Gray Lane Kalispell, MT 59901

Telephone: (Home) 752-5065 (Work)

Installer: Northwest Excavation & Trucking License No. 148

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: Pressure-dosed, shallow-capped system per DEQ approval.

Parcel Description:

Legal: S30 T27 R27 Lot 44 of Thompson Rainbow Estates

Address or Location: 253 Rainbow Lake Road

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1500 gallons Drainfield Size: 195 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL PRESSURE-DOSED, SHALLOW CAPPED SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to back[illegible] [illegible]ste[illegible] Any system not inspected by the Department or its designated representative prior to clos[illegible] [illegible]allation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may [illegible] [illegible]d/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.


Lot 45
Prop corner
1/4 mile
Lot 46
Rainbow Lake Road to highway 2
Proposed well
140 FT
gravel drive
State Land
LOT 47
45'
7'
34'
110FT
150
Secondary Replacement Field
150
20FT Force Main
500
1500
20FT
Future cabin
Existing gravel Drive
Power line
200 Amp Service
Existing
Well
Gravel drive
Power line
To boat Ramp
Upper Thompson Lake Road
prop. corner