PERMIT

Issue Date: 06/24/96 Expiration Date: 06/25/97

Property Owner: Frank Peck c/o: _____

Address: 5106 Highway 2 South Libby, MT 59923

Telephone: (Home) [redacted] (Work) _____

Installer: Julius Robertson License No. 5

____ New Installation XX Existing System

____ Repair XX Replacement ____ Extension ____ Other

Describe: _____

Parcel Description:

Legal: SW 1/4 NW 1/4 NE 1/4 S35 T30 R31

Address or Location: 5106 Highway 2 South Libby, MT

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size: 150 lineal feet

INSTALL SYSTEM ACCORDING TO LOT LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3.

Special Instructions: ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.


Issued By: Kendra J. Lind, R.S.

Closure Statement:

I, Julius W. Robertson, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: Julius W. Robertson *Date:* June 26 1996

Title: Installer



RECEIVED
FEB 02 1996
MONTANA DEPT. OF ENVIRONMENTAL QUALITY WATER QUALITY DIVISION

LOT LAYOUT DIAGRAM
BY R.A. PEARSONS RLS 1/2/96