LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 10/01/2010 Expiration Date: 10/02/2011

Property Owner: TVCDC Business Park c/o: Keith Hanson

Address: [redacted]

Telephone: [redacted] (Work)

Installer: Charley Follensbee License No. 96

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: Sand-lined trenches required per DEQ approval statement. System may not serve more that 24 people.

Parcel Description:

Legal: W-1/2 W-1/2 S3 & SE-1/4 NE-1/4 SE-1/4 S4 T36 R27

Address or Location: Lot 11 of TVCDC Business Park

Approved Design Criteria:

Max. Flow: 260 GPD Septic Tank Size: 1000 gallons Drainfield Size: 180 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SAND-LINED SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____


Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.


LOT 12
±1.286 ACRES
1%
LOT 11
±1.265 ACRES
LOT 5
±1.142 ACRES
2%
2%
LOT 10
±1.194 ACRES
LOT 6
±1.139 ACRES
1%
LOT 9
±1.148 ACRES
LOT 7
±1.139 ACRES
<4%
LOT 8
2%
AIRPORT ROAD