LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 07/15/2010 Expiration Date: 07/16/2011

Property Owner: Betty Willman c/o:

Address: [redacted]

Telephone: (Home) [redacted] (Work)

Installer: Owner License No.

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: Using gravelless chambers for installation – sizing reduction allowed per "Drainfield Sizing" below.

Parcel Description:

Legal: SW-1/4 SE-1/4 S24 T30 R31 Parcel A of COS #3206

Address or Location: 2571 Granite Creek Road

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000 gallons Drainfield Size: 336 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, Kendra J. Lind, R.S., have inspected this system and found it to be in compliance with the conditions of the permit and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* *08/16/2010*

Title: *Assistant Sanitarian*


NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

SEPTIC DETAIL LAYOUT
BETTY WILLMAN
2571 GRANITE CREEK ROAD



LINCOLN COUNTY, MONTANA
LOT LAYOUT
C.O.S. 3206
IN THE SW1/4 SE1/4 OF SECTION 34,
TWP. 30 N., R. 31 W., P.M.M.
FOR: JAMES L. & BETTY L. WILLMAN DATE: MARCH 2010

NO WELLS OR SEPTICS WITHIN 100' OF PROPERTY BOUNDARIES


Reviewed by the Local Reviewing Authority
Under contract with the
Department of Environmental Quality/ PCD

Local Reviewer 7/9/10 Date

Accepted under contract

DEQ Representative 7/13/10 Date

EQ # 11-1014



LEGEND

- PT — PERCOLATION SITE
- TP — SOILS PROFILE SITE
- W — WELL SITE (R=100')
- STORMWATER FLOW'
- EXISTING BUILDINGS
- SLOPE
- GRADIENT DIRECTION
- PROPOSED SEPTIC SITE 4-100' TRENCHES 10' APART
- REPLACEMENT SITE 4-100' TRENCHES 10' APART
- 200' MIXING ZONE

GRADIENT DIRECTION

THE LOT OWNER IS RESPONSIBLE FOR THE MAINTENANCE OF ALL STORMWATER STRUCTURES

ALL STORMWATER WILL FLOW INTO THE NATURAL STORMWATER POND

RECEIVED
JUL 12 2010
MT DEQ PUBLIC WATER & SUBDIVISION BUREAU

SCALE
1 INCH = 200 FT.

Davis Surveying Inc.
TROY MONTANA, (406)295-5441

DATE: 03/22/10	Land Projects 2010
DRAWN BY: MDM	FILE: t30r31s34.DWG