LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 03/20/2026 Expiration Date: 03/19/2027 Permit# 26-11012

Property Owner: Sandra Woolley

Mailing Address: [redacted]

Installer: Melvin Smith License #: 99

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of new gravity system for 3 Bedroom House.

Legal: S16, T33 N, R34 W, COS 4885, ACRES 20.1, E2SWNE

Property Address: 1169 Rocky Draw Rd., Troy, MT 59935 Assessment Code: 11012

DEQ COSA: E.Q.# Date:

Approved Design Criteria: Installation of new gravity system for 3 Bedroom House with 3 Laterals @ 85'.

# of Bedrooms: 3 Septic Tank Size: 1000 gallons Trench Depth: 24"-36"

# of Laterals: 3 Length of Laterals: 85' Trench Width: 24"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Robin Blumberg, RS*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

This permit is not finalized until the system is inspected and the closure statement is signed.

This permit is not a guarantee that the system will function properly for a prescribed period of time.

LINCOLN COUNTY MONTANA


LOT LAYOUT

E 1/2 SW 1/4 NE 1/4 per Book 389 Page 157

The E 1/2 SW 1/4 NE 1/4 Section 16 Twp. 33 N., R. 34 W., P.M.M.

LEGEND

- SOILS PROFILE PIT
- SOIL PERCOLATION SITE
- WELL
- PRIMARY DRAINFIELD 3 - 85' x 24" TRENCHES 10' APART
- REPLACEMENT DRAINFIELD 3 - 85' x 24" TRENCHES 10' APART



2/14/26

Graphic Scale:

0 100 200

(1 inch = 200 ft.)

DAVIS SURVEYING INC.
TROY, MONTANA

DATE: 2/14/26	REV
DRAWN BY: Sol Martin	
Land Projects 2022	
FILE: t333416-sm.dwg	