LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: December 10, 2009 Expiration Date: December 11, 2010

Property Owner: Gerald & Jennifer Coffee c/o:

Address: [redacted]

Telephone: (Home) [redacted] (Work)

Installer: License No.

____ New Installation __XX__ Existing System

_____ Repair __XX__ Replacement_____ Extension _____ Other

Describe: Per DEQ review and approval, replacing existing system with Level II Treatment system to allow for two residences on this property.

Parcel Description:

Legal: S-1/2 S2 T35 R26 Lot 3 of Nesbitt Subdivision

Address or Location: 1905 Mud Creek Road

Approved Design Criteria:

Two Single Family Residences Septic Tank Size: 2000 gallons Level II: Eliminite Model 220 C

Drainfield Size: 1800 Square Feet Recirc. Pump: Hydrymatic OSP50 Dose Pump: Myers ME50

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL LEVEL II SYSTEM ACCORDING TO LAYOUT, DEQ APPROVAL STATEMENT REQUIREMENTS, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

EQ # 10-1305

Reviewed by the Local Reviewing Authority
Under contract with the
Department of Environmental Quality (DEQ)
Local Reviewer 11/30/09

Accepted under contract
DEQ Representative 12/4/09
Date


SITEPLAN
REWRITE OF LOT 3 OF NESBITT SUBDIVISION

S 1/2, SECTION 2, T. 35 N., R. 26 W.
PRINCIPAL MERIDIAN, FLATHEAD COUNTY, MONTANA

50 0 50 100 150
Scale 1" = 100'

The ECO GROUP
ENVIRONMENTAL CONSULTING OFFICE
Maintaining the Balance
285 1st Ave. East North Kalispell, MT 59901
(406) 752-PERC (7372)


Prepared By: Trevor Coudill



Legend


- Soil Profile
- Perc. Site
- Mixing Zone
- Slope across drainfield
- Proposed shared drainfield and Replacement drainfield
- Existing Septic Tank & Lines
- Existing well and 100' isolation zone
- Water line
- Driveways
- Existng Ditch
- Stormwater Retention Swale (30'L x 10'W x 1'D)

Stormwater Retention Swale



*There are no other known wells or drainfields within 100 ft of the perimeter other than those that are already shown.

Typical Road Crosssection



*Stormwater structures to be maintained and repaired by lot owners.

RECEIVED
DEC 02 2009
MT DEQ PUBLIC WATER & SUBDIVISION BUREAU