LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 03/31/2010 Expiration Date: 04/01/2011

Property Owner: Jeff Gilman & Wert Yerger c/o: Jere Johnson

Address: [redacted]

Telephone: (Home) (Work) [redacted]

Installer: Robert Cuffe License No. 141

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: Installing pressure-dosed system to serve two 4-bedroom residential dwellings. As-built drawing to be provided by J. Johnson on completion of installation.

Parcel Description:

Legal: S28 T36 R27 Tract D of Amended Plat of Lot 4 of Lake Othorp Estates -- COS #7043RB

Address or Location: Briggs Shadow Drive

Approved Design Criteria:

Bedrooms: 8 Septic Tank Size: 2250 gallons Drainfield Size: 467 Linear Feet
Dosing Tank Size: 500 gallons

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL PRESSURE-DOSED SYSTEM ACCORDING TO JERE JOHNSON'S DESIGN DETAILS, LOT LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.