LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 11/09/2009 Expiration Date: 11/10/2010

Property Owner: Kelly & Windy Wheeler c/o: Davis Surveying

Address: [redacted]

Telephone: (Home) (Work) [redacted]

Installer: License No.

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: Pressure-dosed sand mound, per Davis Surveying design, for apartment/shop system sized for 3-bedroom total capacity.

Parcel Description:

Legal: SW-1/4 SE-1/4 S7 T35 R27

Address or Location:

Tract 1 of CS #3905 – Court Ordered Division

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000 gallons Drainfield Size: 112 Linear Feet

Dosing Tank Size: 500 gallons

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL PRESSURE-DOSED SAND MOUNT SYSTEM ACCORDING TO DAVIS SURVEYING DESIGN, LOT LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LINCOLN COUNTY, MONTANA
SEPTIC TANK PERMIT
(TRACT 1 OF C.O.S. NO. 3905)
IN THE SW1/4 SE1/4 SECTION 7,
TWP. 35 N., R. 27 W., P.M.M.
FOR: KELLY & WINDY WHEELER DATE: OCTOBER 2009

NO WELLS OR SEPTICS WITHIN 100' OF PROPERTY BOUNDARIES

INDIVIDUAL LOT OWNERS ARE RESPONSIBLE FOR THE MAINTENANCE OF ALL STORMWATER STRUCTURES

TYPICAL SWALE DETAIL
GRAVEL/SAND LINED



ELEVATED SAND MOUND SYSTEM
2-56' TRECHES 3' WIDE
7' APART

LEGEND

- TP — SOILS PROFILE
- W — PROPOSED WELL SITE (R=100')
- STORMWATER SWALE 34' LONG
- EXISTING BUILDING SITE
- SLOPE
- GRADIENT DIRECTION
- PROPOSED SEPTIC SITE 2-56' TRENCHES 7' APART
- REPLACEMENT SITE 2-56' TRENCHES 7' APART
- 100' MIXING ZONE

SCALE
1 INCH = 60 FT.

Davis Surveying Inc.
TROY MONTANA, (406)295-5441

DATE: 10/20/09	Land Projects 2009
DRAWN BY: MDM	FILE: T35R27S7.DWG