Issue Date: 12-5-00 Expiration Date: 12-5-01

Property Owner: PIETER C AND ROSSLYN K WAYCHOFF

Address: [redacted]

Telephone: [redacted] (Work) _____

Installer: Bob Sprague License No. 83

✓ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: _____

Parcel Description:

Legal: Woodland Heights Lot 25 A

Address or Location: 170 Heights Rd

Approved Design Criteria:

Bedrooms 2+1 Septic Tank Size: 1000 gallons Drainfield Size: 240 lineal feet

INSTALL SYSTEM AS PER APPROVED SITE PLAN (LOT LAYOUT) AND LINCOLN COUNTY WASTEWATER REGULATION #3.

Special Instructions: _____

Issued By: Johnny Peterson, RS

Closure Statement:

I, Robert E Sprague *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Robert E Sprague *Date:* 12-12-2000

Title: Installer

RECEIVED
OFFICE
NOV 21 2000
MT DEPT OF ENV QUALITY
PERMITTING & COMPLIANCE DIV

LOT LAYOUT
WOODLAND HEIGHTS LOT 25A

AUGUST 2000
LINCOLN COUNTY, MONTANA

APPROVED
Montana Department of
Environmental Quality
Permitting and Compliance Division
Tim Read 12-1-2000
Reviewer Date

