Issue Date: 03/24/00 Expiration Date: 03/25/01

Property Owner: Dave Wilchelt c/o: Koocanusa Plumbing

Address: [redacted]

Telephone: [redacted] (Work) _____

Installer: Koocanusa License No. 8

XX New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: _____

Parcel Description:

Legal: SW 1/4 S24 T37 R27

Address or Location: Lot 2 in Prairie View Estates

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 195 lineal feet

INSTALL SYSTEM ACCORDING TO LOT LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3.

Special Instructions: ***SAND-LINED TRENCHES REQUIRED. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.***

Issued By: Kendra J. Lind, R.S.

Closure Statement:

I, [illegible], have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: [illegible] *Date:* April 17 2000

Title: Septic Installer

LOT LAYOUT
DAVE WILCHELT
LOT 2 IN PRARIE VIEW ESTATES

