PERMIT

Issue Date: 07/10/00 Expiration Date: 07/11/01

Property Owner: Rolph Zeeb c/o: Joseph Schad

Address: [redacted]

Telephone: (Home) [redacted]

Installer: ~~A. E. (Tony) Brown~~ Douglas Fiel License No. ~~36~~ 84

XX New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: _____

Parcel Description:

Legal: E 1/2 NE 1/4 SW 1/4 S28 T31 R33

Address or Location: N. Milnor Lake Road

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 240 lineal feet

INSTALL SYSTEM ACCORDING TO LOT LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3.

Special Instructions: ***ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.***

Issued By: Kendra J. Lind, R.S.

Closure Statement:

I, _____ have inspected this system and found it to be in compliance with the conditions of the permit and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* 7/16/00

Title: _____

LOT LAYOUT
MIXING ZONE
ROLF ZEEB

