LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 06/11/2026 Expiration Date: 06/10/2027 Permit# 26-6771D

Property Owner: Hermanns Family Holdings Corporation

Mailing Address: [redacted]

Installer: DJ Welch License #: 155

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of new gravity system for 8 Bedroom Lodge.

Legal: S34, T31 N, R33 W, COS PM 7063, PARCEL B, ACRES 99.98

Property Address: 1021 Swanson Lodge Rd., Troy, MT 59935 Assessment Code: 6771

DEQ COSA: E.Q.# Date:

Approved Design Criteria: Installation of new gravity system for 8 Bedroom Lodge with 5 Laterals @ 100' with reduction for chambers. 1000 Gallon Tank, 1500 Gallon Tank, and Grinder pump.

# of Bedrooms: 8 Septic Tank Size: 1000+1500+Grinder Pump Trench Depth: 24"-36"

# of Laterals: 5 Length of Laterals: 100' Trench Width: 24"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. Reduction given for chambers. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Robin Blumberg, RS*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.


Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Robin Blumberg *Date:* 7/10/26

This permit is not finalized until the system is inspected and the closure statement is signed.

This permit is not a guarantee that the system will function properly for a prescribed period of time.



Septic Tank Permit

Lincoln County Montana

Parcel B per C.O.S. 7063RB

In the E ½ W ½ of Section 34,

Twp. 331 N., R. 33W., P.M.M

For:

Hermanns Family

Holdings Corp

Date: October 13, 2025