LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 07/10/2026 Expiration Date: 07/09/2027 Permit# 26-224

Property Owner: Clay Moose

Mailing Address: [redacted]

Installer: Tony Berget License #: 26

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of gravity system for 1 Bedroom House.

Parcel Description:

Legal: YAAK MEADOWS, S31, T36 N, R31 W, BLOCK 002, ACRES 0.78, LOT 21

Property Address: 1466 Tamarack Ln., Troy, MT 59935 Assessment Code: 224

DEQ COSA: EQ# 27-72-679 Date: 6/2/72

Approved Design Criteria: Installation of gravity system for 1 Bedroom House with 1 Lateral @ 65'. The well to be at least 125' from river and at least 100' from drainfield.

# of Bedrooms: 1 Septic Tank Size:1000 Trench Width: 24"

# of Laterals: 1 Length of Laterals: 65' Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Robin Blumberg, R.S.*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Robin Blumberg *Date:* 7/30/26

This permit is not finalized until the system is inspected and the closure statement is signed.

This permit is not a guarantee that the system will function properly for a prescribed period of time.

Assessment Code _____

