LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 07/09/2026 Expiration Date: 07/08/2027 Permit# 26-53127

Property Owner: David and Constance Puttkemery

Mailing Address: [redacted]

Installer: Cory Persson License #: 197

Approved Work: (Check One) ☐ New Installation ☒ Existing System

☐ Replace Drainfield ☒ Replace Tank ☐ Extension

Describe: Installation of 1000 Gallon Tank to an existing system.

Parcel Description:

Legal: BERNARD ESTATES, S13, T36 N, R27 W, ACRES 4.568, LOT 2 PM 6334

Property Address: 872 Lundeen Rd., Eureka, MT 59917 Assessment Code: 53127

DEQ COSA: EQ# 25-1758 Bernard Estates Date: 10/17/2025

Approved Design Criteria: Installation of 1000 Gallon Tank to an existing system.

# of Bedrooms: 5 Septic Tank Size:1000 Gallon Additional Tank Trench Width: 24"

# of Laterals: 4 Length of Laterals: 100 Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. Reduction given for chambers. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: Robin Blumberg, R.S.

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Robin Blumberg *Date:* 7/16/26

This permit is not finalized until the system is inspected and the closure statement is signed.

This permit is not a guarantee that the system will function properly for a prescribed period of time.

Lot 4

LOT LAYOUT

