LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 9/9/2026 Expiration Date: 9/8/2027 Permit# 26-6708

Property Owner: Patti Haaland

Mailing Address: [redacted]

Installer: Stanley May License #: 194

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of gravity system for 1 Bedroom House.

Legal: S28, T31 N, R33 W, COS 2775, PARCEL A, ACRES 2.754

Property Address: 32359 Bull Lake Rd., Troy, MT 59935 Assessment Code: 6708

DEQ COSA: E.Q.#19-1683 Haaland RSR Date: 4/10/19

Approved Design Criteria: Installation of gravity system for 1 Bedroom House with grinder pump to drainfield with 2 Laterals @35' with reduction for chambers.

# of Bedrooms: 1 Septic Tank Size: 1000 & Grinder Trench Width: 24"

# of Laterals: 2 Length of Laterals: 35' Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, Circular DEQ-4, and COSA(If Applies). Reduction given for chambers. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Robin Blumberg, RS*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: John Blankley *Date:* 9/23/26

This permit is not finalized until the system is inspected and the closure statement is signed.

This permit is not a guarantee that the system will function properly for a prescribed period of time.

Haaland
32359 Bull Lake Rd
Troy

