LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 05/07/04 Expiration Date: 05/08/05

Property Owner: Dick & Gayle Skees c/o: Irene & Mike Daniels; Rich & Melanie Miller

Address: [redacted]

Telephone: (Home) [redacted] (Work) [redacted]

Installer: Hadley's Excavating License No. 100

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: System for bathhouse for family camp -- 10-person camp facility --maximum wastewater flow of 320 gallons per day.

Parcel Description:

Legal: N-1/2 SW-1/4 SE-1/4 S24 T33 R26

Address or Location: 1706 Jim Creek Road

Approved Design Criteria:

Maximum Flow: 320 GPD Septic Tank Size: ~~1000~~ 1500 gallons Drainfield Size: ~~200~~ 400 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kendra J. Lind, R.S.

Closure Statement:

I, Daryl J. Hadley, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Daryl J. Hadley Date: 5/21/04

Title: Pres. Hadley's Excavating Inc.

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

SITE PLAN

"SKEES BATHOUSE"

LINCOLN COUNTY

N1/2 SW1/4 SE1/4 SEC. 24, T. 33N., R. 26W., P.M.M.

HOR. SCALE - 1" = 200'

