



Water Supply Requirement

(to be completed by the Authority Having Jurisdiction)

- The proposed subdivision is within the Fire response jurisdiction of: _____
(Agency Name)
- Subdivision Name: _____ Major _____ Minor _____
- There is adequate water supply for the AHJ either on site or within the approved travel distance.
INITIAL _____
- An approved on-site water supply is required to be installed by the developer that is capable of supplying a minimum of 1,000 gallons per minute for 30 minutes (30,000-gallon storage).
INITIAL _____ (Underground tanks, above ground elevated tanks etc.)
- An approved on-site water supply is required to be installed by the developer that is capable of supplying a minimum of 1,500 gallons per minute for 30 minutes (45,000 gallon storage).
INITIAL _____
- Municipal water supply shall be extended to the proposed subdivision meeting AWWA and City of _____ standards. (This may require annexation)
INITIAL _____
- Payment-in-Lieu of water supply in the amount of \$ _____ meets the requirement for water supply mitigation. Payment-in-lieu of water supply shall be held by _____ (**agency name**) for the specific purpose of structure and wildland fire protection, along with maintaining existing water supply tenders and water points.
INITIAL _____
- All Dwelling unit structures shall be equipped throughout the structure with an approved NFPA 13D fire protection sprinkler system complying with the code edition at time of construction.
INITIAL _____

AHJ Representative Names (2 required)

Print _____, _____

Signatures _____, _____

Date: _____